

Eau Claire Fire & Rescue
News Media Report



Date: 04/12/17 Dispatch Time: 21:35 Incident Number: 17 - 2534

Location: 2824 Richard Dr

Incident type: ☒ Fire ☐ Hazardous Materials ☐ Mass Casualty
☐ Auto Casualty ☐ Other _____

Alarms: ☒ 1st Alarm ☐ 2nd Alarm ☐ 3rd Alarm ☐ Special Call

Engine(s) Responding: 3 Rescue/Medical vehicle(s): 1

Command Vehicle(s): 1 Number of Personnel Responding: 12

Injuries: Civilian(s) 0 Firefighter(s): 0

Transported by Ambulance: ☐ Yes (number _____) ☐ No Where: NA

Fatalities: ☐ Yes (number _____) ☒ No

Evacuation: ☒ Yes ☐ No Comments: Both sides of the duplex evacuated

Relocation: ☒ Yes ☐ No Note: Red Cross assisting

Mutual Aid: ☐ Given ☐ Received (units) ☒ N/A

Business Name:

Occupant Information

Name:

Address:

Phone:

Property Owner Information

Name:

Address:

Phone:

Structure Type: Home

Area of Origin: Under Investigation

Under Investigation: ☒ Yes ☐ No By Whom: ECFD

Probable Cause: Electrical issue

Damage Estimate: \$2500 (structure & contents)

Narrative – See next page

Eau Claire Fire & Rescue

News Media Report



Narrative:

Eau Claire Fire Department (ECFD) responded to a reported structure fire.

On arrival, crews made entry into the duplex residence and located an overheated and smoking electrical panel in the basement. A power pole near the residence also had a tripped fuse and small fire. Power was out in numerous neighboring homes.

Xcel energy responded to the scene for repairs to the electrical system.

ECFD crews ventilated the affected side of the duplex and found no fire extension.

Red Cross was responding to the scene to assist the residents.

Officer: Battalion Chief Steve Vargo
Eau Claire Fire Department